

Classification Report



BASEC Client **Energya Power Cables Factory Egypt**

Report No. M4CPRT2198 Classification

Number of pages in this Report: 7

Issue Date **31 October 2019**

Items Tested 2 samples of Power Cable

Specification(s) BS EN 13501-6:2014

Authorised by: I McGuinness

Laboratory Manager

Issue Date: 31 October 2019

This Classification Report does not represent type approval or certification of the product.
This Classification Report shall not be reproduced except in full, without written approval of the laboratory.

British Approvals Service for Cables
Presley House
Presley Way
Crownhill
Milton Keynes
MK8 0ES UK
T: 01908 267300
F: 01908 267255
E: mail@basec.org.uk
W: www.basec.org.uk



5950



Notified Body No. 2661

Introduction

This classification report defines the classification assigned to the product, power cable, in accordance with the procedures given in BS EN 13501-6:2014.



CLASSIFICATION OF REACTION TO FIRE FOR ELECTRIC CABLES IN ACCORDANCE WITH BS EN 13501-6:2014

Sponsor:	Energya Power Cables Factory Egypt
Prepared for:	Energya Power Cables Factory Egypt, 10th of Ramadan City, Industrial Zone, Area A1, Cairo
Prepared by:	British Approvals Service for Cables, Presley House, Presley Way, Crownhill Milton Keynes, MK8 0ES, United Kingdom
Notified Body No.	2661
Product name:	BS 6724 Family 5 (LSF)
Classification report No.	M4CPRT2198 Classification
Issue number:	1
Date of issue:	31 October 2019

This classification report consists of 7 pages and may only be used or reproduced in its entirety.

BASEC Report No M4CPRT2198 Classification

Details of classified product

General

The BS 6724 Family 5 (LSF) cables are classified in accordance with the procedures given in BS EN 13501-6:2014 and is defined as a power cable according to BS EN 50575:2014+A1:2016.

Product description

The power cables 'BS 6724 Family 5 (LSF)' are described in Sample details below.

Traceability

The test samples were submitted by the manufacturer and received on 2 September 2019 & 25 October 2019

Sample details

Parameter	Details
Test sponsor	Energys Power Cables Factory Egypt
Manufacturer of sample	Energys Power Cables Factory Egypt
Place of manufacture	10th of Ramadan City, Industrial Zone, Area A1, Cairo
Cable submitted for test	
BS 6724 5x50mm LSF SWA	Five core power cable. Class 2 (stranded) copper conductors, XLPE Insulation, filler, binder tape, LSHF bedding, steel wire armour, binder tape, LSHF sheath. OD = 45.1mm
BS 6724 5x70mm LSF SWA	Five core power cable. Class 2 (stranded) copper conductors, XLPE Insulation, filler, binder tape, LSHF bedding, steel wire armour, binder tape, LSHF sheath. OD = 47.5mm

BASEC Report No M4CPRT2198 Classification

Reports & results in support of this classification

Reports

Name of Laboratory	Name of test sponsor	Test reports Nos	Test method/field of application rules
BASEC	Energya Power Cables Factory Egypt	M4CPRT2198 M3CPRT2198	BS EN 60332-1-2:2004+A11:2016 BS EN 50399:2011+A1:2016

Results

BS 6724 5x50mm LSF SWA

Test method	Parameter	No. tests runs	Results	
			Continuous parameter	Compliance parameters
BS EN 50399:2011 +A1:2016	FS	1	0.96m	$\leq 1.5\text{m} = \text{B2ca}$ Compliant
	THR _{1200s}		21.0MJ	$\leq 30\text{MJ} = \text{Cca}$ Compliant
	Peak HRR		28.0kW	$\leq 30\text{kW} = \text{B2ca}$ Compliant
	FIGRA		49.5W/s	$\leq 150\text{W/s} = \text{B2ca}$ Compliant
	TSP _{1200s}	1	22.3m ²	$\leq 50\text{m}^2 = \text{s1}$ compliant
	Peak SPR		0.05m ² /s	$\leq 0.25\text{m}^2/\text{s} = \text{s1}$ compliant
BS EN 50399:2011 +A1:2016	Flaming droplets/particles	1	>10s	flaming drops >10s = d2 Compliant
BS EN 60332-1-2:2004 +A11:2016	H	1	80mm	$\leq 425\text{mm} = \text{Eca}$ compliant

BASEC Report No M4CPRT2198 Classification

Results

BS 6724 5x70mm LSF SWA

Test method	Parameter	No. tests runs	Results	
			Continuous parameter	Compliance parameters
BS EN 50399:2011 +A1:2016	FS	1	1.16m	$\leq 1.5\text{m} = \text{B2ca}$ Compliant
	THR _{1200s}		23.0MJ	$\leq 30\text{MJ} = \text{Cca}$ Compliant
	Peak HRR		35.8kW	$\leq 60\text{kW} = \text{Cca}$ Compliant
	FIGRA		45.8W/s	$\leq 150\text{W/s} = \text{B2ca}$ Compliant
	TSP _{1200s}	1	16.1m ²	$\leq 50\text{m}^2 = \text{s1}$ compliant
	Peak SPR		0.04m ² /s	$\leq 0.25\text{m}^2/\text{s} = \text{s1}$ compliant
BS EN 60332-1-2:2004 +A11:2016	Flaming droplets/particles	1	>10s	flaming drops >10s = d2 Compliant
	H	1	87mm	$\leq 425\text{mm} = \text{Eca}$ compliant

BASEC Report No M4CPRT2198 Classification

Classification and field of application

Reference of classification

This classification has been carried out in accordance with BS EN 13501-6:2014.

Classification

The power cables in relation to reaction to fire behaviour are classified:

C_{ca}

The additional classification in relation to smoke production is:

s1

The additional classification in relation to flaming droplets / particles is:

d2

The additional classification in relation to acidity is:

-

The format of the reaction to fire classification for electric cables is:

Fire Behaviour		Smoke Production			Flaming Droplets			Acidity	
C _{ca}	-	s	1	,	d	2	,	-	-

Reaction to fire classification: C_{ca}-s1,d2

The classification assigned to the products in this report is appropriate to a declaration of conformity by the manufacturer within the context of system 3 attestation of conformity and CE marking under the Construction Products Regulation.

The test laboratory has, therefore, played no part in sampling the product for the test, although it holds appropriate references, supplied by the manufacturer, to provide for traceability of samples tested.

BASEC Report No M4CPRT2198 Classification

Field of application

This classification is valid for the power cables described in 'Sample details' and listed below as determined in the extended application process according to PD CLC/TS 50576:2016.

Brand Name	Cable Identification	Number of Cores	Conductor size	Reaction to Fire Classification
Energys Power Cables Factory Egypt	BS 6724 Family 5 (LSF)	5	50mm ² -70mm ²	C _{ca} -s1,d2

This classification is valid for cables for general application in construction works subject to reaction to fire requirements.

Limitations

This classification will be valid whilst;

- The test methods remain unchanged,
- The product standard or technical approval remains unchanged,
- Constructional or material modifications do not exceed limits of the field of application.

The manufacturer has made a declaration, which is held on file, that the product placed in the marketplace, named in the product description section of this report and produced at the manufacturing plant listed therein, is exactly the same as the product that was tested.

This classification document does not represent type approval or certification of the product.

--- END OF REPORT ---