



الموضوع : اختبار كابيل نحاس جهد ٣٠/١١ ك.ف.
قطاع ١٠٠*١ مم ٢

السيد المهندس / رئيس مجلس الادارة
شركة انيرجيا لكابلات الطاقة

تحية طيبة وبعد ،،،

ايها الى خطابكم بتاريخ ٢٠١٧/٩/١٢ والمرفق صورته بخصوص الموضوع عاليه .

نتشرف بالاحاطه بأنه قد تم إجراء الاختبارات المطلوبة وتم إعداد التقرير الفني رقم (٢٠١٧/٣١٢) المتضمن نتائج الاختبارات . علما بان قيمة تكاليف إجراء الاختبارات هى مبلغ وقدره ٥٧٠٠٠ جنيه (فقط وقدره سبع وخمسون الف جنيها مصريا لاغى) شاملة ١٤ % ضريبة القيمة المضافة تسدد بشيك باسم الشركة القابضة لكهرباء مصر- مركز أبحاث الجهد الفائق- فى مقابل استلام التقرير بموقع مركز أبحاث الجهد الفائق .

وتفضلوا بقبول فائق الاحترام ،،،

رئيس قطاع
المعامل والبحوث والاختبارات

م/ محمد سليم سلطان

٢٠١٧

عضو مجلس الادارة المتفرغ
لشئون شركات التوزيع

م/ الحسينى الحسينى الفار

مرفقات :

عدد

(١) التقرير الفني المكون من عدد (١٣) صفحة .

TEST REPORT

REPORT No. (312/2017)

▪ **CLIENT :** **ENERGYA POWER CABLES-ELSEWEDY HELAL.**

▪ **Report Date :** 1 / 10 /2017

▪ **Place :**

- Extra High Voltage Research Center.
- Internal Code : TO - AC - 17 - 09 - 13 - 01.

▪ **Requirements:**

- Type tests according to IEC 60502-2 (2014) .

▪ **Standard Specification:**


- IEC (60502-2),(60228),(60811-1-1),(60811-1-2),(60811-1-3) , (60811-3-1)

▪ **Description of the Specimen :**

- 18/30 kV Power cable with the following specification:
 - Manufacturer : Energya power cables-Elsewedy Helal.
 - Type : 18/30 kV/CU/ XLPE/ATA /PVC - 1 × 800 mm²
 - No. of Phases : 1 Phases.
 - Insulation : XLPE
 - Conductor Material : Copper
 - Conductor cross-section: 800 mm²
 - Screening Material : Copper Tape + Copper wire + Aluminum Tape.
 - Sheath Material : PVC ST2
 - Sheath Color : Black.

▪ **Description of the Equipment:**

- High voltage reactor - 400 kV - 5000 KVA - 50 Hz - Type: (RSK) - Serial No. 204322/99.
- PD detector - Type: (FE57).
- Tan δ measurement devise - Type: dobel- M4000 - Serial No. 029700917.
- Impulse voltage generator 800 kV - 40 kJ - Type IP40/800M..
- Air oven up to 300 °C - Type BINDER - Serial No. 02-32772.
- Universal testing machine 100 kN -Type Lloyod - Model LR100Kplus Serial No. 108322.



M. Rabu

▪ **Test Samples:**

- Test sample were choose under the responsibility of the client.

▪ **Tests:**

1- Electrical Type Tests on Completed Cable:

- 1.1 Bending test, followed by partial discharge test.
- 1.2 Tan δ measurement.
- 1.3 Heating cycle test followed by partial discharge test.
- 1.4 Impulse test followed by a voltage test.
- 1.5 Voltage test for 4 h.
- 1.6 Resistivity of semi-conducting screens.

2- Non-Electrical Type Tests on Cable Components :

1. Measurement of thickness of insulation
2. Measurement of thickness of non-metallic sheath.
3. Tests for determining the mechanical properties of insulation before and after ageing
4. Tests for determining the mechanical properties of non-metallic sheaths before and after ageing
5. Additional ageing test on pieces of completed cables.
6. Test for resistance of PVC sheath to cracking (heat shock test).
7. Hot set test for XLPE insulation.
8. Shrinkage test for XLPE insulation.
9. Loss of mass test on PVC sheaths of type ST2.

▪ **Test Method and Results:**

1- Electrical Type Tests on Completed Cable:

1.1 Bending test, followed by partial discharge test:

1.1.1 Bending test:

- The test cable was subjected to a bending test at 2000 ambient temperature for at least one complete turn and unwound without axial rotation . This cycles carried out three times.

Outer diameter of cable D (mm)	Diameter of conductor d (mm)	Requirement of bending diameter $< 15(D+d)\pm 5\%$ (mm)	Hub diameter of drum (mm)
70.4	34.1	2194.5	2000



M. Rabe

1.1.2 Partial discharge test:

- The test cable was subjected to a partial discharge test in accordance with clause 18.2.5 of IEC 60502-2 . The test voltage was raised gradually to and held at $2 U_0$ for 10 s and then slowly reduced to $1.73 U_0$ and the magnitude of the discharge was measured
- The measured value of the partial discharge level is shown in the following table

Test voltage (kV)	Maximum partial discharge level (PC)	Measured partial discharge (PC)
31.14	5	1.86

- The test results met the requirements.

1.2 Tan δ measurement:

- Another sample of test cable was subjected to a **Tan δ** measurement in accordance with clause 18.2.6 of IEC 60502-2 . The test cable was heated by passing a current through the conductor until it reached a steady temperature, which was 98 °C. The **Tan δ** was measured at a power frequency voltage of at least 2 kV at the temperature specified above.
- The measured value of Tan δ is shown in the following table

Test voltage (kV)	Maximum allowable value for $\tan \delta (x 10^{-4})$	Tan $\delta (x 10^{-4})$ [Measured value]
2	40	17

- The test results met the requirements.

1.3 Heating Cycle followed by partial discharge test:

1.3.1 Heating Cycle:

- The test cable was subjected to a heating cycle voltage test in accordance with clause 18.2.7 of IEC 60502-2 . The test cable was heated by passing a current through the conductor until it reached a steady temperature, which was 98 °C. The heating was applied for 5 h. The conductor temperature was maintained within the stated temperature limits for 2 h of each heating period. This was followed by 3 h of natural cooling. The cycle of heating and cooling was carried out 20 times.
- The result of the heating cycle is shown in the following table:

No. of heating cycles	Required conductor temperature (°C)	Heating		Cooling time (h)
		Total heating time (h)	Duration of heating at 98 °C(h)	
20	$95 \leq t \leq 100$	5	2	3

The test results met the requirements.

M. Rabe



1.3.2 Partial discharge test

- After the last heat cycle, partial discharge was measured for the test cable at ambient temperature in accordance with clause 18.2.5 of IEC 60502-2 . The measurement was carried out as mentioned above under item 1.1.
- The measured value of the partial discharge level is shown in the following table:

Test voltage (kV)	Maximum partial discharge level (PC)	Measured partial discharge (PC)
31.14	5	1.57

- *The test results met the requirements.*

1.4 Impulse test followed by a voltage test:

1.4.1 Impulse Test:

- The test cable was subjected to a lightning impulse voltage withstand test in accordance with clauses 18.2.8 of IEC 60502-2 (2005). The test was performed on the sample at a conductor temperature of 98 °C. The cable withstood 10 positive and 10 negative voltage impulses with peak value of 170 kV without failure.
- *The results were illustrated by the Figures in page No. (9:12) of this report.*
- *The test results met the requirements.*

1.4.2 Voltage Test:

- After the impulse voltage test, the test cable was subjected to a voltage test of was 3.5 U_o. The voltage was increased gradually to 63 kV and maintained for 15 min. in accordance with clause 18.2.8 of IEC 60502-2 .
- The result of the voltage test is shown in the following table:

Applied voltage (kV)	Frequency (Hz)	Duration (min)	Observations
63	50	15	No breakdown

The test results met the requirements.



M. Rabie

1.5 Voltage test for 4 h:

- The test cable was subjected to the voltage test for 4 h in accordance with clauses 18.2.9 of IEC 60502-2 . This test was made at ambient temperature. A power frequency voltage was applied for 4 h to the test cable between the conductor and screen. The test voltage was 4 U_n . The voltage was increased gradually to 72 kV and maintained for four hours.
- The result of the voltage test is shown in the following table:

Applied voltage (kV)	Frequency (Hz)	Duration (hour)	Observations
72	50	4	No breakdown

- *The test results met the requirements.*

1.6 Resistivity of semi-conducting screens:

- The measurement of the resistivity of the semi-conducting screens was carried out in accordance with clause 18.2.10 of IEC 60502-2 . The resistivity of extruded semi-conducting screens applied over the conductor and over the insulation was determined by measurements on test pieces taken from the core of a sample of cable as manufactured and a sample of cable which has been subjected to the ageing treatment to test the compatibility of component materials specified in IEC 60502-2. The measurements were made at a temperature of 90 ± 2 °C.
- The result of the Resistivity of semi-conducting screens are shown in the following table:

Item	Unit	Requirement	Measured Value
Conductor screen			
- without ageing	Ωm	≤ 1000	25.43
- after ageing	Ωm	≤ 1000	16.92
Insulation screen			
- without ageing	Ωm	≤ 500	14.59
- after ageing	Ωm	≤ 500	6.12

- *The test results met the requirements.*



M. Rabie

2- Non-Electrical Type Tests on Cable Components :

2.1. Measurement of thickness of insulation

- The thickness of insulation was measured in accordance with clause 19.2 of IEC 60502-2
- The result of the measurements are shown in the following table:

Thickness of insulation	Unit	Requirement	Measured Value
- minimum	mm	≥ 7.1	8.17
- $(t_{max} - t_{min}) / t_{max}$		≤ 0.15	0.08

- *The test results met the requirements.*

2.2. Measurement of thickness of non-metallic sheath:

- The thickness of non-metallic sheath was measured in accordance with clauses 19.3 of IEC 60502-2.
- The result of the measurements are shown in the following table:

Thickness of non-metallic sheath	Unit	Requirement	Measured Value
- minimum	mm	≥ 3.4	4.16

- *The test results met the requirements.*

2.3. Tests for determining the mechanical properties of insulation before and after ageing:

- The mechanical properties of insulation before and after ageing were determined in accordance with clause 19.4 of IEC 60502-2 .

Item	Unit	Requirement	Measured Value
Without ageing			
- Min. tensile strength	N/mm ²	12.5	19.50
- Min. elongation	%	200	392.5
After ageing in air oven			
-Min. tensile strength	N/mm ²	—	22.38
-Max. variation with samples without ageing	%	± 25	14.76
-Min. elongation	%	—	458.76
-Max. variation with samples without ageing	%	± 25	16.88

- *The test results met the requirements.*

2.4. Tests for determining the mechanical properties of non-metallic sheaths before and after

M. Rabie



ageing

- The mechanical properties of the outer sheath before and after ageing were determined in accordance with clause 19.4 of IEC 60502-2.
- The results of the mechanical properties of non-metallic sheaths before and after ageing are shown in the following table.

Item	Unit	Requirement	Measured Value
Without ageing			
- Min. tensile strength	N/mm ²	12.5	15.08
- Min. elongation	%	150	193.6
After ageing in air oven			
-Min. tensile strength	N/mm ²	12.5	15.99
-Max. variation with samples without ageing	%	± 25	6.03
-Min. elongation	%	150	202.9
-Max. variation with samples without ageing	%	± 25	4.79

- *The test results met the requirements.*

2.5. Additional ageing Test on Pieces of Completed Cable:

- Ageing tests on pieces of completed cable were carried out in accordance with clause 19.5 of IEC 60502-2 (2005).
- The results of the mechanical properties of completed cable are shown in the following table:

Item	Unit	Requirement	Measured Value
Insulation			
-Min. tensile strength	N/mm ²	—	18.65
-Max. variation with samples without ageing	%	± 25	- 4.35
-Min. elongation	%	—	352.4
-Max. variation with samples without ageing	%	± 25	- 10.21
Sheath			
-Min. tensile strength	N/mm ²	12.5	17.94
-Max. variation with samples without ageing	%	± 25	18.96
-Min. elongation	%	150	182.7
-Max. variation with samples without ageing	%	± 25	-5.64

- *The test results met the requirements.*

2.6. Test for resistance of PVC sheath to cracking (heat shock test).

M. Rabee



- The test for resistance of PVC sheath to cracking (heat shock test) was carried out in accordance with clause 19.11 of IEC 60502-2 .
- The result of the heat shock test for the PVC sheath is shown in the following table.

Over sheath thickness (average)	Mandrel diameter (mm)	Number of turns	Air oven temperature (°C)	Duration (hour)	Observations
3.99	8	4	150	1	No crack

- *The test results met the requirements.*

2.7. Hot set test for XLPE insulation:

- A hot set test for the XLPE insulation was carried out in accordance with clause 19.13 of IEC 60502-2 .
- The results of the hot set test for the XLPE insulation are shown in the following table:

Item	Unit	Requirement	Measured
- Elongation under load	%	≤ 175	135
- Permanent elongation	%	≤ 15	9

- *The test results met the requirements.*

2.8. Shrinkage test for XLPE insulation:

- A shrinkage test for XLPE insulation was carried out in accordance with clause 19.18 of IEC 60502-2 .
- The result of the shrinkage test for XLPE insulation is shown in the following table.

Distance L between marks (mm)	Air oven temperature (°C)	Duration (hour)	Maximum shrinkage (%)	Shrinkage measurement (%)
200	130	1	4	3

- *The test results met the requirements.*

2.9. Loss of mass test on PVC sheaths ST₂:

- A loss of mass test on PVC sheaths of type ST₂ was carried out in accordance with clause 19.6 of IEC 60502-2 .
- The result of the loss of mass test on PVC shown in the following table.

Number of sample	Air oven Temp. (°C)	Duration (hour)	Requirement mg/cm ²	Measured value mg/cm ²
3	100	168	1.5	1.4

- *The test results met the requirements.*



M. Rakab

▪ **CONCLUSION :**

- **The power cable 18/30 kV/CU/ XLPE /ATA/PVC -1 × 800 mm² manufactured by Energya Power Cables-Elsewedy Helal Fulfilled the requirements of tests mentioned in this report according to IEC 60502-2 (2014).The customer must check of carrying out other remaining test specified in IEC standard and not included in this report.**

▪ **Notes:**


- Tests were carried out on the above specimen only without any responsibility concerning other untested specimens.
- The tests were carried out without any obligation on Egyptian Electricity Holding Company
- This test report shall not be reproduced except in full, without written approval of EHVRC.
- After finishing the tests (E.H.V.R.C) isn't obligated to return the test sample within two month's from report receive.

▪ **TEST ENGINEERS:**



GENERAL MANGER




10 / 1 / 2017

Nahla .

18/30 KV Power Cable 1*800mm², CU/ XLPE/ATA/PVC

Energys Power Cables Elsewedy Helal

Polarity:(+ve)

TO-AC-17-09-13-01




Fig. 1

Ch1: 1
Up = 167.7 kV
T1 = 4.165 μs
T2 = 56.15 μs




Fig. 2

Ch1: 1
Up = 167.6 kV
T1 = 4.165 μs
T2 = 56.09 μs




Fig. 3

Ch1: 1
Up = 167.7 kV
T1 = 4.172 μs
T2 = 56.06 μs




Fig. 4

Ch1: 1
Up = 167.7 kV
T1 = 4.135 μs
T2 = 56.08 μs





Fig. 5

Ch1: 1
Up = 167.2 kV
T1 = 4.097 μs
T2 = 56.21 μs



18/30 KV Power Cable 1*800mm², CU/ XLPE/ATA/PVC

Energya Power Cables Elsewedy Helal

Polarity:(+ve)

TO-AC-17-09-13-01




Fig. 6

Ch1: 1
Up = 167.6 kV
T1 = 4.156 μs
T2 = 56.16 μs




Fig. 7

Ch1: 1
Up = 167.5 kV
T1 = 4.157 μs
T2 = 56.13 μs




Fig. 8

Ch1: 1
Up = 167.5 kV
T1 = 4.152 μs
T2 = 56.18 μs




Fig. 9

Ch1: 1
Up = 167.5 kV
T1 = 4.155 μs
T2 = 56.09 μs





Fig. 10

Ch1: 1
Up = 167.5 kV
T1 = 4.169 μs
T2 = 56.18 μs



Khary

18/30 KV Power Cable 1*800mm², CU/ XLPE/ATA/PVC

Energys Power Cables Elsewedy Helal

Polarity:(-ve)

TO-AC-17-09-13-01




Fig. 1

Ch1: 1
Up = -155.0 kV
T1 = 4.182 μs
T2 = 56.03 μs




Fig. 2

Ch1: 1
Up = -166.6 kV
T1 = 4.192 μs
T2 = 56.14 μs




Fig. 3

Ch1: 1
Up = -167.3 kV
T1 = 4.178 μs
T2 = 56.10 μs




Fig. 4

Ch1: 1
Up = -166.8 kV
T1 = 4.113 μs
T2 = 56.28 μs




Fig. 5

Ch1: 1
Up = -166.7 kV
T1 = 4.101 μs
T2 = 56.33 μs



18/30 KV Power Cable 1*800mm², CU/ XLPE/ATA/PVC

Energys Power Cables Elsewedy Helal

Polarity:(-ve)

TO-AC-17-09-13-01




Fig. 6

Ch1: 1
Up = -166.8 kV
T1 = 4.131 μs
T2 = 56.29 μs




Fig. 7

Ch1: 1
Up = -167.0 kV
T1 = 4.157 μs
T2 = 56.26 μs




Fig. 8

Ch1: 1
Up = -166.9 kV
T1 = 4.154 μs
T2 = 56.21 μs




Fig. 9

Ch1: 1
Up = -167.1 kV
T1 = 4.161 μs
T2 = 56.17 μs




Fig. 10

Ch1: 1
Up = -167.1 kV
T1 = 4.160 μs
T2 = 56.19 μs



energya
CABLES
A Division of Energya Industries
ELSEWEDY HELAL

Energya power Cables
انيرجيا لكابلات الطاقة
ELSEWEDY HELAL

السيد الدكتور مهندس / رئيس قطاع معامل أبحاث الجهد الفائق

تحية طيبة وبعد

برجاء التكرم بالموافقة على اختبار عينة كابل 1X800 نحاس جهد 18/30 وإجراء اختبار Type Test عليها ونحن على إستعداد تحمل كافة التكلفة المطلوبة .

ولسيادتكم جزيل الشكر ووافرا لأحترام

يعتمد


م / محمد كمال

مدير الجودة

مركز أبحاث الجهد الفائق
سابق رقم / ٢١١
لتقرير الفحص رقم ١٥ / ١٧

energya

POWER CABLES
A Division of Energya Ltd.



مرکز أبحاث الجهد العالي

مرفق رقم / ٢١٠

لتصميم النموذج رقم ٢١٠/٢١٨

View		Type		CU/XLPE/ATA/PVC	
Voltage		Standard		IEC 60228, 60811 & 60502-2	
Description		Thickness		Diameter (Approx.)	
		mm		Mm	
1	Compacted Circular Copper	0.1 (Before Application)		34.1 ± 0.4	
2	Smoothing Tape				
3	Inner Semi-Conductive	8 (Nominal)			
4	XLPE Insulation				
5	Outer Semi-Conductive				
6	Semi-Conductive Tape			1.3	
7	Copper Wires Screen	0.1			
8	Copper Tape Binder - O.H				
9	Non-Conductive Tape	1.16 (Min)			
10	PYG Bedding				
11	Aluminum Tape Armour	2.28 (Min)		70.4 ± 3	
12	PVC Sheathing				

Not to Scale

Eng. Mohamed Abdel Sattar

مرکز ابحاث الجهد الفائق
سرق رقم / ٢١٢
التقرير الفوق رقم ٢١٢ / ٧٠٤

مراجعة

عبدالله