

We hereby, energya SPECIALTY CABLES declare under our sole responsibility that the

Product: Fire resistance cable
Manufacturer Name: energya SPECIALTY CABLES
Manufacturer Address: 10th of Ramadan City, Zone A – 1 , Egypt
Rating: 300/ 500 V
Trade Mark: energya SPECIALTY CABLES EI-Swed y Helal
Description: CU/MICA/LSZH/OS/LSZH
Color: Red
Sufficient samples of the product have been tested and found to be in conformity with the current standard (number and edition): BS 6387:1994 clause 11.1, 11.2& 11.3
As shown in the test report (reference No.): 243/7524657 from BSI

This declaration of conformity statement has been established by Quality Assurance Department supported with Test Report number 243/7524657 issued by BSI laboratory in accordance with **BS 6387:1994 clause 11.1 Resistance to fire alone (category C), 11.2 Resistance to fire with water (Category W) and 11.3 Resistance to fire with mechanical shock (category Z)**

This declaration of conformity statement of test results of testing samples of the product is complying with the required test.

And it implies an assessment of the whole production, technical and quality documentation and fulfillment of standard requirements.

Hesham El- Awady
Quality Manager
Date : March 31st 2011

energya SPECIALTY CABLES

Office: 1 El fayoum St, Heliopolis - Cairo - Egypt Tel.: (202) 24195064, 24195065 Fax: (202) 24195066

Factory : 10th of Ramadan City , Zone A-1 , Tel .: (2015) 41007314 Fax: (2015) 410400

Web Site: www.energya.com